

Emergency Lighting Test Log

Ref. National Fire Protection Association – 2000 Edition Life Safety Code (LSC)

Sec. 7.9.3. A functional test shall be conducted on every required emergency lighting system at 30-day intervals for not less than 30 seconds. An annual test shall be conducted on every required battery-powered emergency lighting system (includes battery-operated exit signs) for not less than 1 ½ hours. Equipment must be fully operational for the duration of the test. (Attach floor plan to indicate location of battery-powered emergency lights).

Annual Test Date:	Individual Conducting Test:	Emergency lighting system tested for 1 ½ hours and operating properly. *
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No

Monthly Test Date:	Individual Conducting Test:	Emergency lighting system tested for 30 seconds and operating properly. *
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No

* Remarks: Please explain any equipment system failures and corrective action that was taken.
